



NOTES:

1. All driveways must meet the current Town driveway requirements and NCDOT requirements for spacing, sight distance, and offsets from property lines and intersections.
2. Special conditions may warrant exceptions to this detail. Subject to approval by Town Engineering, Public Works Director or NCDOT.
3. Concrete mountable island shall be installed in accordance with NCDOT Standard Detail 852.01.
4. Driveway aprons shall be constructed of a min. 4" thick, 3000 psi concrete or 6" ABC base course with a 2" asphalt surface course.



TOWN OF NAGS HEAD
 DEPARTMENT OF ADMINISTRATION
 P.O. BOX 99
 NAGS HEAD, NC 27959
 252.441.7016 • www.nagsheadnc.gov

**TYPICAL COMMERCIAL DRIVEWAY DETAIL
 WITH MOUNTABLE ISLAND DETAIL**

(FOR DRIVEWAY CONNECTIONS TO S. CROATAN HWY.)

SCALE: NONE
 ISSUE DATE: 7-9-2015
 REVISION DATE: 1-3-2019
 SHEET NO: 1 OF 1
 DRAWN BY: DMR

DETAIL NO.:

202